Safety Reference

Flammable Cabinet Storage Guidance

- All flammable chemical containers shall be stored in the flammable cabinet when not in use.
- Flammable cabinet doors shall be kept closed except when retrieving or placing chemicals in the cabinet.
- Only flammable and combustible chemicals shall be stored in the flammable cabinet.
- Storage within the flammable cabinet shall not exceed the cabinet's rated capacity (gallons).
- Flammables that are still in unopened manufacturer original packaging do not need to be stored in flammable cabinet. i.e., case of 6 aerosol spray paint cans in an unopened cardboard box.
- Once original manufacturer packaging is opened, then both the chemical in use and the remaining contents of the package must be stored in the flammable cabinet. i.e., associate opens box of 6 aerosol spray paint cans to do container door touch up. The spray paint can in use and the other 5 spray cans must all be stored inside the flammable cabinet.
- Never store miscellaneous non-flammable chemicals such as antifreeze, car wash soap, etc. in the flammable cabinet. Rather these products should either be stored in an organized manner on a shelf or in a non-flammable rated cabinet.
- Lids of chemical containers shall be securely in place between uses.
- Empty safety fuel cans do not need to be stored in a flammable cabinet, but full or partially full safety fuel cans do and should be kept to a minimum.
- Post the SDS Online QR code on the flammable cabinet doors for quick access to SDS when needed.

Pods Enterprises, LLC

Scan to access an SDS